

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.


No. S.H./2024/ 4

Date : 01/01/2025

It is certified that an inspection team headed by Dr. Rashmi Batra, Dy. Civil Surgeon, Gurugram and inspection done by Dr. Kanika, Nodal Officer, School health, Gurugram of **Shemford Futuristic School, Malibu Town Sector-47 , Gurugram , on dated 26-12-2024 .** They Checked the Water test report Submitted by School and found that the School has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

This Certificate is valid for a period of One Year.

Signature with Seal:


Civil Surgeon
Gurugram
11/1/25

Name: _____

Designation: _____

To,

Shemford Futuristic School,

Malibu Town Sector-47,

Gurugram,

(Name & Address of the Institution)

DISTRICT PUBLIC HEALTH LAB

DISTRICT CIVIL HOSPITAL, GURUGRAM

D.No. 356/2024/Mucio

Dated 30/12/24

To

The S.M.O./M.O. Incharge,

CHC/PHC CS Gurugram

SUB : WATER SAMPLES REPORT

In reference to your letter No. CS/12/2024/24

Dated 23/12/2024 vide which you have sent water samples for bacteriological examination, the result of each is as under :

Sr. No.	Place of Collection	Result	PCC
①	Shenford Futuristic School, Malika Towne, Sec 47 Gm	FIT	2/100ml Class II
②	SD Adarsh Public School Near - Ghanteshwar Mandi - Gm	FIT	2/100ml Class II
4.			
5.			

P.C.C. Presumptive coliforms count

* Above samples are tested by multiple tube methods.

INTERPRETATION

PCC Per 100ml	CLASS	REMARK	RESULT
0	I	EXCELLENT	FIT
1 - 3	II	SATISFACTORY	FIT
4 - 9	III	SUSPICIOUS	UNFIT
> 9	IV	UN SATISFACTORY	UNFIT

* The Result given above are related to samples as received & tested in Lab..

Dr. Manish Bhatnagar
MBBS, MD - Microbiology
Medical Officer, Gurugram
MCI - 11-40072
30/12/24